



MCL	REPORTING UNITS	CHEMICAL	ENTRY #	ANALYSES RESULTS	DLR
1000	ug/L	Aluminum (Al) (ug/L)	01105	960	50
6	ug/L	Antimony (ug/L)	01097	ND	6.0
10	ug/L	Arsenic (As) (ug/L)	01002	2.3	2.0
1000	ug/L	Barium (Ba) (ug/L)	01007	140	100
4	ug/L	Beryllium (ug/L)	01012	ND	1.0
5	ug/L	Cadmium (Cd) (ug/L)	01027	ND	1.0
50	ug/L	Chromium (Total Cr) (ug/L)	01034	ND	10
1000	ug/L+	Copper (Cu) (ug/L)	01042	ND	50
300	ug/L+	Iron (Fe) (ug/L)	01045	620	100
	ug/L	Lead (Pb) (ug/L)	01051	ND	5.0
50	ug/L+	Manganese (Mn) (ug/L)	01055	ND	20
2	ug/L	Mercury (Hg) (ug/L)	71900	ND	1.0
100	ug/L	Nickel (ug/L)	01067	ND	10
50	ug/L	Selenium (Se) (ug/L)	01147	ND	5.0
100	ug/L+	Silver (Ag) (ug/L)	01077	ND	10
2	ug/L	Thallium (ug/L)	01059	ND	1.0
5000	ug/L+	Zinc (Zn) (ug/L)	01092	ND	50

## ADDITIONAL ANALYSES

	ug/L	Boron (ug/L)	01020	170	100
10000	ug/L	Nitrate + Nitrite as Nitrogen(N) (ug/L)	A-029	ND	400
1000	ug/L	Nitrite as Nitrogen(N) (ug/L)	00620	ND	400
150	ug/L	Cyanide (ug/L)	01291	ND	100
	ug/L	Vanadium (ug/L)	01087	4.9	3.0
	ug/L	Perchlorate (ug/L)	A-031	ND	4.0

+ Indicates Secondary Drinking Water Standards